

CERTIFICATE

The company

FALKE Heating & Cooling

Tepeören Mevki
Akdeniz cad. No. 7
34959 ORHANLI-TUZLA
TURKEY

with its production site in

Orhanli-Tuzla

hereby receives the confirmation that the product/s

Solar collectors

of the type

F 190

conforms to

DIN EN 12975-1:2006-06

DIN EN 12975-2:2006-06

Specific CEN KEYMARK Scheme Rules for Solar Thermal Products version 10.07 (Edition: 2009-02)

and is granted the licence to use the marks



in conjunction with the Registration No. below.

Registration No.: 011-7S774 F

This Certificate is valid until 2014-05-31.

Annex

to the Certificate with Registration No. 011-7S774 F, dated 2009-05-07

Technical data

See data sheet, part of the test report of 2009-05-05

Note(s):

- The freeze resistance test according to DIN EN 12975-2, clause 5.8 was not necessary. According to the manufacturer's declaration, the certified solar collectors may be used in frost exposed areas only in combination with appropriate frost protection mixtures.
- The optional impact resistance test according to DIN EN 12975-2, clause 5.10 was not carried out.

Testing laboratory / Inspection body

Institut für Solartechnik SPF
Hochschule für Technik
Rapperswil
Oberseestrasse 10
8640 RAPPERSWIL
SCHWEIZ

Test report(s)

No. C1085LPEN, No. C1085QPEN dated 2009-05-05

502